April, 2018	
	Amity Regional School District No. 5
CLEAN	
SAFE	Facilities Department Monthly Report
HEALTHY	Completed Projects:
SCHOOLS Amity Regional School District No. 5 25 Newton Road Woodbridge, CT 06525 Phone: 203-397-4817 Fax: 203-397-4864	 The heater in the septic system pit at Amity Middle School, Orange Campus failed. A new one was purchased and installed by in-house personnel. Spring preventive maintenance was performed on all District air handlers. The insulation on the exterior ductwork of the gymnasium air handling unit at Amity Middle School, Bethany Campus, was replaced due to damage to the exterior sheathing. The chillers and cooling tower at Amity Regional High School were prepared for the cooling season. All maintenance and tube punching was completed by in-house personnel. The chillers at the middle schools were serviced, including coil cleaning, by in-house personnel. Storm drains in the senior parking lot area had become clogged with sand and debris. The lines were jetted and cleaned by our drain contractor. Two large trees that presented a danger of falling limbs were removed at Amity Middle School, Bethany Campus. A motion sensor for the lighting in the art room at Amity Regional High School was replaced by in-house personnel. A science room at Amity Regional High School reported a lack of air flow. In-house personnel trouble shot the issue and calibrated the VAV box and replaced a faulty thermostat. The sinks in the art room at Amity Middle School, Orange Campus, were not draining properly. The traps were disassembled and cleaned by in-house personnel.
	<u>Projects in process:</u>
	 We are waiting for an appropriate time to perform a full PM on the main breakers at Amity Regional High School, which will require an extended power outage. This will be scheduled on a Saturday during the summer.
<u> S</u>	Outstanding issues to be addressed:
	• None at this time.